



# Progress® multiLAYER

## Installation Instructions



\*Installation by qualified electricians only! Lack of appropriate knowledge and competence may result in incorrect installation, putting the safety of users at risk.



Individual sealing rings may be removed as follows:

1. Use a pair of long-nose pliers to pierce the dust protection.
2. Remove dust protection using pliers.
3. Use the pliers to grip individual sealing rings.
4. Remove sealing rings as required to suit the cable diameter.
5. If necessary in order to enable mounting on a pre-fabricated cable, sealing inserts may be cut straight using a sharp knife.
6. When re-assembling sealing inserts if required, the rings must be brought precisely together as shown in the picture.

**Progress multiLAYER NPB**



**Progress multiLAYER Synthetic**

